

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7136-0065:141 Page 1 of 1

CATEGORY: Audible Devices for Hazardous Locations

LISTEE: Faraday Inc., 805 S. Maumee Street, Tecumseh, MI 49286
Contact: Steven A. Blohm (517) 423-2111

DESIGN: Model 4110, 4120, 4130, 4138 and 4139 vibrating horns. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Suitable for indoor and outdoor except for Models 4120 and 4230 are for indoor use only.

MARKING: Listee's name or "FOS", model number, electrical rating and UL label.

APPROVAL: Listed as electronic vibrating horns for use with separately listed compatible fire alarm control units. Suitable for hazardous locations Class I, Group C and D; Class II, Group E, F and G and Class III.

06-03-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager